

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 01:06 pm

PWS ID: UTAH27061 **Name:** PINE VALLEY MT FARMS
Legal Contact: PINE VALLEY MT. FARMS **Rating:** Approved
LEONARD HULET **Rating Date:** 06/22/1992
Address: 100 E WELLS FARGO RD **Activity Status:** Active
BROOKSIDE, UT 84782
Phone Number: 435-574-2983
City Served (Area):
County: WASHINGTON COUNTY
System Type: Community **Last Inv Update:** 06/20/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 12/15/2009 **Total Dsgn Cap:**
Population: 100 **Surveyor:** ROBERT BEERS **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	HULET, LEONARD		435-574-2983	435-673-3631	leonardh1@live.com

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unknown	0	56
			56 Total Svc Connections

Storage

Total Storage: 425,000 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	TANK	Ground	425,000 GAL	Steel		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL #1	Active	WL	10	425 GPM	500 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	WELL #2	Active	WL		278 GPM	400 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.